



Housing Project - Bldg. A

Results of Sonic Tests on Piles

Pile	Details	Length (m)	Reflectogram	Remarks
Average	20/11/17 C:3900m/s Amp:10 F:9 Planned:11.0m Avg:29	10.9m		Average of all piles
84	06/04/14 C:3900m/s Amp:5.5 F:4 Planned:11.0m Avg:40	11.2m		
85	06/04/14 C:3900m/s Amp:11 F:4 Planned:11.0m Avg:26	11.3m		
86	06/04/14 C:3900m/s Amp:9.5 F:6 Planned:11.0m Avg:16	11.0m		